

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

2ND 1360

RECEIVED 12 SEP 2017

Part I

Dispatch No D-735 / EE C-12 / DUSIB / 2017 Date: 12/9/17

Sub: **Testing of CC cubes of mix for 28 days Compressive Strength.** 1:1.4:3

AL No.36/WK/7205(127)/EEC-12/DUSIB/2016-17 /D- 969 dated 16.11.2016

NOW: Pay and Use JSC

SH: Construction of 35 Seater JSC at JJ Cluster Saheed Bhagat Singh Camp, Paschim Vihar
(Project ID 000007101).

- 1 Details from where sample is collected From Site
- 2 Name of Circle/Division Circle-IV/C-12
- 3 Name of Junior Engineer _____
- 4 Name of Assistant Engineer A.K. Sardana
- 5 Name of Executive Engineer Sh. Kamal Singh
- 6 Name of Contractor/Agency M/s Daya Const. Co.
- 7 Name of Officer collecting sample A.K. Sardana
- 8 Date of collection: 14/8/2017
- 9 Date of testing: 11/9/2017
- 10 Required strength: Rec. C-1.4:3
- 11 No. of specimen sent for testing: 03
- 12 Size of specimen: 15X15X15 cm
- 13 Mark of specimen: Sample AE

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked Sample AE have been taken in my presence which represent-----quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D- 1583
Test No. 1360 Date: 12.9.17

Date: 14/09/17

Date of Receipt: 12/9/17
Date of testing: 12/9/17
Concrete Mix: 1:1.4:3

Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	<u>8555 gm</u>	<u>225</u>	<u>63.50 T</u>	<u>282.22</u>	<u>277.04</u>	
2.	<u>8492 "</u>	<u>225</u>	<u>62.00 T</u>	<u>275.56</u>		
3.	<u>8488 "</u>	<u>225</u>	<u>61.50 T</u>	<u>273.33</u>		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC Lab)

DUSIB-Vikas Kutir ITO

Assistant Engineer (QC Lab)

Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
Vikas Kutir, ITO, New Delhi-02

Copy to:-