

Quality Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

R No 1289
RECEIVED 04 SEP 2017

Part I

No. D-62/AEVI/EEC4/DUSIB/2017

Date... 04/09/17

A.L. No. -31/WD/4541/(20)/AE-VI/EE-C-4/DUSIB/2017-18/D-337

Dated: 13-07-2017

Sub: Testing of Bricks for Compressive Strength / Dimension

- 5. Name of work: Construction of BVK/Community Hall.
- 6. Sub Head : Renovation of communityHall at 80 sq yard Harijan Colony Tilak Nagar (Project ID:000008048)

- 3. Name of Circle / Division: Circle-II/C-4
- 4. Name of Junior Engineer:
- 5. Name of Assistant Engineer: Sh. Yashvir Singh
- 6. Name of Executive Engineer: Sh. Anil Aggarwal
- 7. Name of Contractor / Agency: M/S Yogesh Tyagi
- 8. Name of Officer Collecting Sample: Sh. Yashvir Singh
- 9. Date of collection / Date of filling frog:
- 10. Date of testing:
- 11. Identification Mark:
- 12. Class Designation:
- 13. No. of specimen sent for testing:

31-8-17
4-9-17
MBF
7.5
5 Nos

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked shakti.ing.17 tag have been taken in my presence which represent 20% CRP. Mor quantity of work / supply made at site / store.

Signature of J.E.

Signature of Contractor

Signature of Officer
Taking sample (EE / AE)

Part II

No. SE(QC)/AE(Lab)/2007/D-1497
 Test No. 1289 Date 4.9.17
 Date of Receipt 04/9/17

Date..... 04/09/17.....

(A) COMPRESSIVE STRENGTH

Date of testing upto 04/9/17

S.No.	Area (Sqcm)	Crushing Load (In MT)	Compressive Strength (In Kg / Cm2)	Average Compressive Strength
1.	<u>237.44</u>	<u>18.50T</u>	<u>77.91</u>	ACCEPTABLE <u>82.25</u> <u>kg/cm²</u>
2.	<u>237.30</u>	<u>19.00T</u>	<u>80.07</u>	
3.	<u>242.89</u>	<u>20.00T</u>	<u>82.34</u>	
4.	<u>244.08</u>	<u>22.00T</u>	<u>90.12</u>	
5.	<u>247.50</u>	<u>22.00T</u>	<u>80.87</u>	

(B) DIMENSION

Date of testing upto.....

not asked for

Only testing has been conducted in this laboratory, the sample have been collected ,cured and handed over by the field staff of the division.

04/9/17
 Assistant Engineer (QC) Lab.
 DUSIB.

Assistant Engineer (QC)
 Delhi Urban Shelter Improvement Board
 Govt. of N.C.T. of Delhi
 ITC, New Delhi-02

Copy to:

- 1. EE/C-4
- 2.

The Assistant Engineer (QC)
 Quality Control Lab, DUSIB
 Vikas Kuteer. ITO, New Delhi