

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

RNO - 681

RECEIVED 22 JUN 2017

Part I

Dispatch No NET/EEC-12/DUSIB/17-18/92 Date: 22/6/17

Sub: Testing of CC cubes of mix for 28 days Compressive Strength. RCC(1:1.5:3)

AL No. 58/WK/7205(148)/EEC-12/DUSIB/2016-17/D- 216 dated 10.03.2017

Name of work: EIUS.

SH: Providing and laying CC pavement and construction of drains in Punjab Migrant Relief Camp/Basti at Peera Garhi, Rohtak Road (Project ID 000008443).

- 1 Details from where sample is collected slp
- 2 Name of Circle/Division Circle-4/C-12
- 3 Name of Junior Engineer IEI
- 4 Name of Assistant Engineer A.K. Sardana
- 5 Name of Executive Engineer Sh. K.K. Sharma
- 6 Name of Contractor/Agency M/S Hanuman Construction Co
- 7 Name of Officer collecting sample A.K. Sardana
- 8 Date of collection: 22/6/17
- 9 Date of testing: 22/6/17
- 10 Required strength: RCC 1:1.5:3
- 11 No. of specimen sent for testing: 03
- 12 Size of specimen: 15X15X15 cm
- 13 Mark of specimen: E/22/5

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked E/25 has/have been taken in my presence which represent 15 quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (JE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D-

Date:

Test No. 681 Date: 22.6.17

Date of Receipt: 22.6.17

Date of testing: 22.6.17

Concrete Mix: 1:1.5:3

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8264	225	60.00	266.66	} 275.55	EE May Correlate According
2.	8281	225	62.00	275.56		
3.	8293	225	64.00	284.44		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC Lab.)

Delhi Urban Shelter Improvement Board

Delhi Urban Shelter Improvement Board

30, N. C. T. of Delhi

Copy to:-