

PN<sup>o</sup> 2132  
RECEIVED 26 DEC 2017

To  
The Assistant Engineer (QC)  
Quality Control Lab., DUSIB  
Vikas Kuteer, ITO, New Delhi

Part I  
Dispatch No AE-V/19/DUSIB/2017-18/D-124 Date: 26/12/2017  
Sub: Testing of CC cubes of mix ---M-15--- for 28 days Compressive Strength.

A. L. No. 04/LOA/EE/C-9/DUSIB/2017-18/D-1014 Dated: 9/8/17

Name of work: F.I.S  
Sub Head: Raising of deteriorated lanes by P.C.C. Pavement & Const. of drain in 55 Basti Nehru Camp Labor Camp

1. Details from where sample is collected ----- from site -----
2. Name of Circle/Division ----- 3/C-9 -----
3. Name of Executive Engineer ----- Sh. Phool Singh -----
4. Name of Assistant Engineer ----- Mahender Pal (A.E.) -----
5. Name of Junior Engineer -----
6. Name of Contractor/Agency ----- M/s Pooja Builders -----
7. Name of Officer collecting sample ----- Mahender Pal (A.E.) -----
8. Date of collection: ----- 22/11/17 -----
9. Date of Testing ----- 20/12/17 -----
10. Quantity of sample sent for testing: ----- 3 Nos. -----
11. Required strength: ----- as per CPWD specifications -----
12. No. of specimen sent for testing: ----- 03 Nos. -----
13. Size of specimen: ----- 15cm X 15cm X 15cm -----
14. Mark of specimen: ----- RPB-A -----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked (A) has/have been taken in my presence which represent 20 cum quantity of works/supply made at site/store.

Signature of AE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

Part II TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18/D- 2491 Date: 29/12/17  
Test No. 2132 Date:  
Date of Receipt: 26/12/17  
Date of testing: 26/12/17  
Concrete Mix: M-15 Days test: 34 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8380 gm	225	44.50T	197.79	192.59 kg/cm <sup>2</sup>	EE May Correlate Accordingly!
2.	8546 "	225	44.27	195.56		
3.	8522 "	225	41.50T	184.44		

Tested in my presence  
Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

[Signature] 26/12/17  
Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO

Copy to:-  
EE/C-9

Assistant Engineer (QC)  
Delhi Urban Cha...