

The Assistant Engineer (QC)  
Quality Control Lab, DUSIB  
Vikas Kuteer. ITO, New Delhi

2978

R.No: 3057

Part I

No. 233./A.E.-III./C-2/DUSIB

26 MAR 2018

Date: 26/03/2018

Sub: Testing of CC cubes of mix .....M-25..... for 7 / 28 days Compressive Strength.

AL. No:- WF/4766(19)/AE-III/C-2/2016-17D-527 Dated:-30/10/2017

1. Name of work: Imp. of SC/ST Basties.

Sub Head:- Providing & Laying cement concrete pavement & construction of drains by raising the level in main lanes of SC/ST Basti at C-5 Khatik Mohalla Swarn Park Mundka.

- 2. Details from where sample is collected: From Site.....
- 3. Name of Circle / Division: ...C-2.....
- 4. Name of Junior Engineer: Sh. Ravinder Kumar
- 5. Name of Assistant Engineer: Sh. P.S. Johar
- 6. Name of Executive Engineer: Sh. S.C. Sharma
- 7. Name of Contractor / Agency: M/S L.K. Builders & Supplier.
- 8. Name of Officer Collecting Sample: Sh.P.S. Johar
- 9. Date of collection : 25/02/2018
- 10. Date of testing: 25/03/2018 / 26/03/2018
- 11. Required Strength: .....
- 12. No. of specimen sent for testing: 1 No. ....
- 13. Size of specimen: 15x15x15 cm
- 14. Mark of specimen: Sign.....

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked ... Sign ... has / have been taken in my presence which represent ..... quantity of work / supply made at site / store.

Signature of J.E.

Signature of Contractor

Signature of Officer Taking Sample (EE / AE)

Part II

No. SE(QC)/AE(Lab)/2008/D- 3420

Test No. 3057 Date: 26/03/18

Date of Testing: 26/3/18

Concrete Mix ..... M:25

Date: 26/03/18

Date of Receipt: 26/3/18

Day Test: 29 days

S. No	Wt. of specimen (In gms.)	Area (In Sq. cm) mm <sup>2</sup>	Compressive Strength		Average Strength (In Kg/sq. cm) N/mm <sup>2</sup>	Remarks
			Load (Tonnes) KN	Comp. strength (In Kg/sq. cm) N/mm <sup>2</sup>		
1.	8390 gm	2250	688	30.58	N/mm <sup>2</sup>	
2.	8450 v	2250	700	31.11		
3.	8482 v	2250	712	31.64		

Tested in my presence

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the concerned division.

COPY TO:-

1 BE/C-2

2. 0/c

Assistant Engineer (QC) Lab.  
DUSIB, Vikas Kuteer, ITO.

Assistant Engineer (QC)  
Quality Control Lab, Vikas Kuteer, ITO, New Delhi