

TD - 9649

The Assistant Engineer (QC)  
Quality Control Lab, DUSIB  
Vikas Kuteer. ITO, New Delhi

NO. 3034

2959

23 MAR 2018

**Part I**

No. 225/AE-III/C-2/DUSIB

Date: 23/03/2018

**Sub: Testing of CC cubes of mix ..... M-25 ..... for 7/28 days Compressive Strength.**




**AL No:- WF/4766(19)/AE-III/C-2/2016-17D-527 Dated:-30/10/2017**

1. Name of work: Imp. of SC/ST Basties.

Sub Head:- Providing & Laying cement concrete pavement & construction of drains by raising the level in main lanes of SC/ST Basti at C-5 Khatik Mohalla Swarn Park Mundka.

2. Details from where sample is collected:	From Site.....
3. Name of Circle / Division:	...C-2.....
4. Name of Junior Engineer:	Sh. Ravinder Kumar
5. Name of Assistant Engineer:	Sh. P.S. Johar .
6. Name of Executive Engineer:	Sh. S.C. Sharma
7. Name of Contractor / Agency:	M/S L.K. Builders & Supplier.
8. Name of Officer Collecting Sample:	Sh.P.S. Johar
9. Date of collection :	..... 23/02/2018.....
10. Date of testing:	..... 23/03/2018.....
11. Required Strength:	.....
12. No. of specimen sent for testing:	..... 1 Nos.....
13. Size of specimen:	..... 15 x 15 x 15.....
14. Mark of specimen	..... Sign.....

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked ... Sign ... has / have been taken in my presence which represent ..... quantity of work / supply made at site / store.

 Signature of J.E.	 Signature of Contractor	 Signature of Officer Taking sample (EE / AE)
--	--	--

**Part II**

No. SE(QC)/AE(Lab)/2006/D- 3401

Date: 26/03/18


Test No. 3437 Date: 23/03/18

Date of Receipt: 23/3/18

Date of Testing: 23/3/18

Concrete Mix ..... M-25 Day Test: 28 days

S. No	Wt. of specimen (In gms.)	Area (In Sq. cm) mm <sup>2</sup>	Compressive Strength		Average Strength (In Kg/sq.cm) N/mm <sup>2</sup>	Remarks
			Load (Tonnes) kN	Comp. strength (In Kg/sq.cm) N/mm <sup>2</sup>		
1.	8446 gm	2250	670	29.78	29.81 N/mm <sup>2</sup>	
2.	8522 gm	2250	680	30.22		
3.	8496 gm	2250	662	29.42		



**Tested in my presence**

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the concerned division.

COPY TO: EE/C-2  
o/c

  
Assistant Engineer (QC) Lab.  
DUSIB, Vikas Kuteer, ITO.

23/3/18