

R.No. 2915

RECEIVED 22 MAR 2017

To
The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

Part I
Dispatch No. D-44/AE-II/C12/DUSIB/17 Date: 22/03/17

Sub: Testing of CC cubes of mix M-15 for 728 days Compressive Strength.

A. L. No. 28/WK/7205(117)/EEC-12/DUSIB/2016-17/D-840 3/10/14 Date: 22/03/17
1. Name of work: ELUS Rest-Remodelling of 3rd & 4th layers C.C. Paved
Stn. & Coal up chowk at J.J. cluster near Railway C&P station.
Block (Block-c) PLOm 5531

- 2. Details from where sample is collected
- 3. Name of Circle/Division
- 4. Name of Junior Engineer
- 5. Name of Assistant Engineer
- 6. Name of Executive Engineer
- 7. Name of Contractor/Agency
- 8. Name of Officer collecting sample
- 9. Date of collection:
- 10. Date of testing:
- 11. Required strength:
- 12. No. of specimen sent for testing:
- 13. Size of specimen:
- 14. Mark of specimen:

SHP
SE-A/C-12
A.K. Sharma
Sh. K.K. Sharma
Sh. Mukesh Kumar Goyal
A.K. Sharma
22/2/2017
22/3/2017
M-15
3m
1545X15

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample samples marked _____ has/have been taken in my presence which represent _____ quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample

TEST REPORT

Date: 23/03/17

Part II
No. SE(QC)/AE(Lab.)/2016-17/D-4772
Test No. 2915 Date: 22.3.17
Date of Receipt: 22.3.17
Date of testing: 22.3.17
Concrete Mix: M-15

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8009	225	41.50	184.44	186.88	Correlate accordingly
2.	7974	225	43.50	193.33		
3.	8023	223	41.00	182.22		

Moh Tested in my presence
Only testing has been conducted in this laboratory. The sample/samples has/have been collected & handed over by the field staff of the concerned division.

22/3/17
Assistant Engineer (QC)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to: