

The Assistant Engineer (QC)
Quality Control Lab DUSIB
Vikas kutir ITO New Delhi

RNO. 0214
RECEIVED 25 APR 2017

Part - I

Dispatch No. 281/PEW/EEC-4/DUSIB/2017-18

Date... 25/4/2017

Sub: **Testing of C.C. cubes of RMC M-20 for 28 days Compressive Strength**

No. AL- 185/WD/4541/372(53) AE W/EEC-4/DUSIB/16-17/D-1376 dt-23-3-2017

Name of work : EDUS

S.H : P/L CC Pavement and improvement of Drainage system in JJ Bashi near Double Storey Sweeper tenements at Raghbir Nagar (Project ID 050003690)

- | | |
|---|---------------------------------------|
| 2. Details from where sample as collected | Form the site |
| 3. Name of circle Division | Circle -2 / C-4 |
| 4. Name of Junior Engineer | Pradeep Agrawal |
| 5. Name of Assistant Engineer | Sh. Yashvir Singh |
| 6. Name of Executive Engineer | Sh. Anil Kumar Aggarwal |
| 7. Name of Contractor/ Agency | <u>M/s Fair Deal Construction Co.</u> |
| 8. Name of Officer collecting sample | Sh. Yashvir Singh AE=IV |
| 9. Date of collection | <u>28-3-2017</u> |
| 10. Date of testing | <u>25-4-2017</u> |
| 11. Required strength | |
| 12. No of specimen sent for testing | 3.00nos |
| 13. Size of specimen | 15cmx15cmx15cm |
| 14. Mark of specimen | <u>SATM & DASH</u> |

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked SATM...has/have been taken in my presence which represent 50 cum quantity of work/supply made at site/store.

[Signature]
Signature of JE
In charge of work

[Signature]
Signature of Contractor

[Signature]
Signature of Officer
taking sample (JE/AE)

Part - II

TEST REPORT

NO. SE(QC)/AE(Lab)/2016-17/D-
Test no. 0214 date. 25.4.17
Date of Receipt 25.4.17
Date of testing 25.4.17
Concrete Mix: M-20

Date.
Days test: 28 days

S.no	Wt of specimen in gms	Area in sq.cm	Compressive strength		Average strength(kg /sq.cm)	Remarks
			Load (Tonnes)	comp. strength (kg./ sq.cm)		
1	8153	225	54.50	242.22	} 242.22	
2	8092	225	53.00	235.56		
3	8084	225	56.00	248.89		

EE May correlate accordingly

Tested in my presence
Only testing has been conducted in this laboratory. The sample/ samples has/have been collected and handed over by the field staff of the concerned division.

[Signature]
Assistant Engineer (QC-Lab)
DUSIB, Vikas kutir ITO
Delhi Urban Shelter Improvement Board
Gov. of N.C.T. of Delhi
ITC, New Delhi-02

Copy To
1 EEIC-4
OLC