

RECEIVED 20 APR 2017

Part I
Dispatch No. ~~3B/AE/C-10/DUSIB/17-18~~ / EE/C-10/DUSIB/17-18 Date: 18-4-17
Sub: Testing of Bricks/Brick tiles for Compressive Strength/Dimension.

L. No. WB/4321/AL-79/EE-C-10/16-N/D-1105 Date:

1. Name of work: MLA LAD fund. (Project id 000008094)
SHE: Development / strengthening of common areas / common facilities / common packages / balconies / courtyard / common stair / toilets block + various facilities in Slum Complexes. K block Swami Dayanand colony
2. Details from where sample is collected: From site C-10/4
3. Name of Circle/Division:
4. Name of Junior Engineer:
5. Name of Assistant Engineer:
6. Name of Executive Engineer:
7. Name of Contractor/Agency:
8. Name of Officer collecting sample: Sh. Satish Chandra
9. Date of collection/Date of filling frog: Sh. Shyam Singh
10. Date of testing: M/s Mehd. Firoz Khan
11. Identification Mark: AE-I, Satish Chandra
12. Class designation: 15/4/17 16/4/17
13. No. of specimen sent for test: 20/4/17 of 1201
14. Specimen relating to work mentioned above is/are sent for testing. It is certified that the samples marked 75 has/have been taken in my presence which represent 5 quantity of work/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE)

TEST REPORT

Lab. No. 0156 Date: 20.4.17
No. of Receipt: 20.4.17
Date of Testing: 20.4.17
Date: 24/04/17

COMPRESSIVE STRENGTH

S. No	Dimensions			Maximum Strength: Failure (T)	Compressive Strength Failure (kg/sq.cm)	Av. Comp Strength Kg/sq.cm
	Length (cms)	Width (cms)	Area (sq.cm)			
	22.60 x	11.40 =	257.64	23.00	89.27	89.65
	22.50 x	11.50 =	258.75	25.00	96.61	
	22.50 x	11.40 =	256.50	24.00	93.56	
	22.40 x	11.50 =	257.60	21.00	81.52	
	22.30 x	11.30 =	251.99	22.00	81.30	

ACCEPTABLE

Checked in my presence
3) DIMENSION TEST FOR 20 BRICKS

Length: _____
Width: _____ NOT ASKED FOR -
Height: _____

Only testing has been conducted in this laboratory. The sample/samples has/have been collected over by the field staff of the concerned division

COPY TO:
2. EE/C-10
2. OIC

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
New Delhi