

DELHI URBAN SHELTER IMPROVEMENT BOARD
GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER(E-2)
1, KILOKARI, RING ROAD, OPP. MAHARANI BAGH N.D.-14

No. EE(E-2)/DUSIB/2014-15/D-680

Dated:- 12.08.2014

Sub:-Clarifications to the queries raised in Pre-Bid meeting held on 06.08.2014 with regard to

Installation, operation, maintenance and management of bio-digester enabled mobile toilet vans in Delhi.

E-tender no. 2014_DUSIB_62406_1.

In reference to pre bid meeting held on 06-08-2014 under the Chairmanship of Chief Engineer-I, DUSIB, GNCT Delhi in the office of CE-I, DUSIB opp. Office of ACP(West), Shivaji Place, Raja Garden, New Delhi-110027. The following queries were raised by the participants present in the pre-bid meeting, the replies/clarifications of the same are given here under.

S.NO	Queries	Clarifications
1	What will be the Minimum capacity of sludgecum Bio-Digester tank with each MTV.	Concessionaire shall design and install sludge cum bio-digester tank of a minimum capacity of 3000 litres with each MTV. In case the Concessionaire feels the necessity for additional provisions even after providing additional sludge tank at any Point of Service as per the provisions of the Concession

		Agreement, the Concessionaire shall notify to DUSIB and DUSIB at its own discretion shall make available space for such additional provision.																																				
2	For claiming from DUSIB concessionaire will raise demand to whom	EE(E-2) DUSIB																																				
3	What will be DRDO specifications	<table border="1"> <thead> <tr> <th>S.no</th> <th>PARAMETERS</th> <th>Limit(Max.)</th> <th>Protocols</th> </tr> </thead> <tbody> <tr> <td>01</td> <td>PH</td> <td>7.0 to 7.2</td> <td>IS: 3025 (P-11)</td> </tr> <tr> <td>02</td> <td>Total Suspended Solids</td> <td>90 to 120 mg/L</td> <td>IS: 3025 (P-17)</td> </tr> <tr> <td>03</td> <td>Total Dissolved Solids</td> <td>350 to 450 mg/L</td> <td>IS: 3025 (P-16)</td> </tr> <tr> <td>04</td> <td>Chemical Oxygen Demand</td> <td>250 to 300 mg/L</td> <td>IS: 3025 (P-58)</td> </tr> <tr> <td>05</td> <td>Biochemical Oxygen Demand (for 3 days at 27 Deg. C)</td> <td>70 to 120 mg/L</td> <td>IS:3025 (P-44)</td> </tr> <tr> <td>06</td> <td>Volatile Solids</td> <td>20 to 30 mg/100 ml</td> <td>IS: 3025 (P-18)</td> </tr> <tr> <td>07</td> <td>Turbidity</td> <td>70 to 90 NTU</td> <td>IS: 3025 (P10)</td> </tr> <tr> <td>08</td> <td>Total Coliform (By MPN Method)</td> <td>300 to 350/100 ml</td> <td>IS: 1622</td> </tr> </tbody> </table> <p>The parameters specified above as amended/revised from time to time by DRDO/DRDE, Gwalior shall apply during operational period of MTV.</p>	S.no	PARAMETERS	Limit(Max.)	Protocols	01	PH	7.0 to 7.2	IS: 3025 (P-11)	02	Total Suspended Solids	90 to 120 mg/L	IS: 3025 (P-17)	03	Total Dissolved Solids	350 to 450 mg/L	IS: 3025 (P-16)	04	Chemical Oxygen Demand	250 to 300 mg/L	IS: 3025 (P-58)	05	Biochemical Oxygen Demand (for 3 days at 27 Deg. C)	70 to 120 mg/L	IS:3025 (P-44)	06	Volatile Solids	20 to 30 mg/100 ml	IS: 3025 (P-18)	07	Turbidity	70 to 90 NTU	IS: 3025 (P10)	08	Total Coliform (By MPN Method)	300 to 350/100 ml	IS: 1622
S.no	PARAMETERS	Limit(Max.)	Protocols																																			
01	PH	7.0 to 7.2	IS: 3025 (P-11)																																			
02	Total Suspended Solids	90 to 120 mg/L	IS: 3025 (P-17)																																			
03	Total Dissolved Solids	350 to 450 mg/L	IS: 3025 (P-16)																																			
04	Chemical Oxygen Demand	250 to 300 mg/L	IS: 3025 (P-58)																																			
05	Biochemical Oxygen Demand (for 3 days at 27 Deg. C)	70 to 120 mg/L	IS:3025 (P-44)																																			
06	Volatile Solids	20 to 30 mg/100 ml	IS: 3025 (P-18)																																			
07	Turbidity	70 to 90 NTU	IS: 3025 (P10)																																			
08	Total Coliform (By MPN Method)	300 to 350/100 ml	IS: 1622																																			
4	What will be minimum man power for O&M for each MTV.	Concessionaire shall provide one Site In-charge per MTV at all times and at least one male and one female sanitary staff for cleaning of maximum 2 MTVs during the Operations Period as specified in the Concession Agreement. However it will be ensured that only female staff shall be deputed for seats to be used by female and vice-versa.																																				
5	Concession Agreement page 3, Recitals	Recitals C, D, E to be read as Not Used																																				
6	Concession Agreement, Clause 15.2 (a) Termination for Concessionaire Event of Default	(iv) Upon Termination by DUSIB on account of occurrence of a Concessionaire Event of Default before the COD, no Termination Payment shall be made to the Concessionaire.																																				
7	Concession Agreement, Clause 15.2 (b) (ii) be	15.2 (b) (ii) Upon Termination of this Agreement by the Concessionaire due to a																																				

	read now as....	DUSIB Event of Default, the Concessionaire shall be entitled to receive from DUSIB, by way of Termination Payment a sum equal to the Total Balance Value of MTV less pending insurance claims, if any.
--	-----------------	--

This shall also form the part of concession Agreement.

C.D. Passi
EE(E-2)DUSIB
Mob.No.-9560596086

DELHI URBAN SHELTER IMPROVEMENT BOARD
GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER(E-2)
1, KILOKARI, RING ROAD, OPP. MAHARANI BAGH N.D.-14

No. EE(E-2)/DUSIB/2014-15/D-687

Dated : 13.08.2014

CORRIGENDUM- No. 2

Sub:- Installation, operation, maintenance and management of bio-digester enabled mobile toilet vans in Delhi.
E-tender no. 2014_DUSIB_62406_1.

Due to Administrative reasons, the bid due date, opening of Key submissions and date for verification of documents have been extended and may now be read as under:

S. No	Event Description	Earlier Date	New / Extended Date
1	Bid due date	20-08-2014 at 3.00 PM	25-08-2014 at 3.00 PM
2	Opening of Key Submission	20-08-2014	25-08-2014 at 3.30 PM Onwards
3	Verification of Documents	25-08-2014	30-08-2014 (11.00 AM to 4.00 PM)

Other Terms & Conditions of the bid documents shall remain the same.

(C D PASSI)
EE, E-2
9560596086